

NOTES

All dimensions in millimetres.

Precast concrete flags to comply with BS.EN.1339:2003.

Flags shall be 60mm thick and except where cutting is necessary of uniform size, 300mm x 300mm.


Item coverage to include for supply and laying 25mm compacted thickness of designation (iii) dry mix mortar bedding course.

Flags shall be laid with a bond of 150 mm. This may be varied where economical use of flags dictate, but shall not be less than 75mm.


All joints shall not be less than 5mm nor more than 10mm width.

Joints shall be filled with designation (i) mortar and hollow key pointed. With coloured flags, a similarly coloured mortar shall be used.


Concrete infill around obstructions should not exceed 25mm in width and should be the full depth of the flag and similarly coloured.



DETAIL OF POINTING



PAVING LAYOUT



SECTIONAL ELEVATION