

## NOTES

All dimensions in millimetres.

Rigid pipes shall be of vitrified clay, precast concrete or similar materials. Non rigid pipes shall be of glass reinforced plastic, thermoplastic or similar materials.

Pipes to be centred in trench.

In situations where a combined french and surface water drain is specified, pipes if perforated, shall be laid with the perforations uppermost.

Material ① to be Type B backfill filter material.

Material ② to be granular pipe bedding material as described in the Specification.

Porous concrete pipes are not permitted.

