

NOTES

All dimensions in millimetres.

Material ① to be well compacted acceptable material.

Material ② to be selected backfill which shall be recycled aggregate or acceptable material free from stones or lumps of clay > 40mm nominal dia.

Material ③ to be sand complying with BS.1200:1976 Table 1, well compacted.

Cable to be centred in trench.

The cable shall be billed and measured separately from the service trench.

